

# Water Sample Collection and Preservation.



- A minimum of 1 litre in a clean plastic water bottle is required for analysis.
- Thoroughly rinse the bottle with water from the sampling area before collecting a representative sample, filling the bottle to the top.
- Samples should be despatched as soon as possible to preserve the validity of the sample. If a sample needs to be held overnight, place in the fridge.